MISSISSIPPI STATE DEPARTMENT OF HEADING JUL 14 AM 9: 06

DUNEAU OF FUDLIC WATER SUITET
CCR CERTIFICATION
CALENDAR YEAR 2015
C. S. + D W ater Company
Public Water Supply Name
PWS # 0110002
List PWS ID #s for all Community Water Systems included in this CCR
fe Drinking Water Act (SDWA) requires each Community public water system to develop a fidence Report (CCR) to its customers each year. Depending on the population served by the

The Federal Sa and distribute a Consumer Con he public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.

Customers were informed of availability of CCR by:	(Attach copy of publication, water bill or other)
☐ Advertisement in local paper (attaulum) Advertisement in local paper (attaulum) On water bills (attach copy of bil ☐ Email message (MUST Email the ☐ Other	ach copy of advertisement) message to the address below)
Date(s) customers were informed:/,	/ / ,
CCR was distributed by U.S. Postal Service or omethods used	other direct delivery. Must specify other direct delivery
Date Mailed/Distributed: / /	
CCR was distributed by Email (MUST Email MSDI As a URL (Provide URL As an attachment As text within the body of the em	
CCR was published in local newspaper. (Attach copy	
Name of Newspaper: The Port Kiliso	n Reveille
Date Published: 06/23/2016	
CCR was posted in public places. (Attach list of local	tions) Date Posted: / /
CCR was posted on a publicly accessible internet site	e at the following address (<u>DIRECT URL REQUIRED</u>):
CERTIFICATION I hereby certify that the 2015 Consumer Confidence Republic water system in the form and manner identified the SDWA. I further certify that the information includ the water quality monitoring data provided to the public water Supply. Name/Title (President, Mayor, Owner, etc.)	above and that I used distribution methods allowed by ed in this CCR is true and correct and is consistent with
Deliver or send via U.S. Postal Service: Bureau of Public Water Supply P.O. Box 1700	May be faxed to: (601)576-7800

Deliv Bure P.O. Jackson, MS 39215

May be emailed to:

CCR Due to MSDH & Customers by July 1, 2016!

water.reports@msdh.ms.gov

2016 JUN 27 PM 1: 36

2015 Annual Drinking Water Quality Report CS&I Water Association PWS#: 0110002 June 2016

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Catahoula Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the CS&I Water Association have received lower susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact Sonny Harpole at 601.437.4304. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Tuesday of the month at 5:00 PM at 3148 Karnac Ferry Rd., Port Gibson, MS.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during the period of January 1st to December 31st, 2015. In cases where monitoring wasn't required in 2015, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) – The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

				TEST RESU	JLTS			
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Radioactiv	e Conta	minants						
5. Gross Alpha	N	2012*	7.31	3.98 - 7.31	pCi/L	0	15	Erosion of natural deposits
7. Uranium ¹	N	2012*	.293	.275293	ug/L	01	30 ¹	Erosion of natural deposits
Inorganic (Contami	inants						
8. Arsenic	N	2014*	.5	No Range	ppb	n/a	10	Erosion of natural deposits; runof from orchards; runoff from glass and electronics production waster

10. Barium	N	2014*	.0119	.00980119) pr	om	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2014*	6.5	1.2 – 6.5	pp	ob	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2012/14*	.6	0	pi	om	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2014*	.774	.73774	pi	om	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2012/14	3	0	p	ob	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Disinfection	n Bv-	Products	<u> </u>		<u> </u>				
81. HAA5	N	2014*	44	No Range	ppb		0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2014*	79.6	No Range	ppb		0	80	By-product of drinking water chlorination.
Chlorine	N	2015	.9	.6– 1.3	mg/l		0 M	DRL = 4	Water additive used to control microbes

^{*} Most recent sample. No sample required for 2015.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

Significant Deficiencies

During a sanitary survey conducted on 9/09/2015, the Mississippi State Department of Health cited the following significant deficiency(s).

Inadequate internal cleaning/maintenance of storage tanks

Corrective actions: MSDH is currently working with this system to return them to compliance since the expiration of the compliance deadline. We anticipate the system being returned to compliance by 6/30/2016.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The CS & I Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

2015 Annual Drinking Water Quality Report C S & I Water Association

PWS#: 0110002

June 2016

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Catahoula Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the CS&I Water Association have received lower sus-

ceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact Sonny Harpole at 601.437.4304. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Tuesday of the month at 5:00 PM at

3148 Karnac Ferry Rd., Port Gibson, MS.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during the period of January 1st to December 31st, 2015. In cases where monitoring wasn't required in 2015, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria. that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

		2		Facead MCL/A	mg i	-ment			
Radioactiv	e Cont	aminan	ts						
5. Gross Alpha	N	2012*	731	3.98 73	1]	pC/A.	[o		15 Ercsion of natural deposits
7. Uranium	14	2012*	293	275 - 29	• 1,	ogri.	a ¹	30	Erosion of natural deposits
Inorganic	Contai	ninants							•
8 Arsenic	ľ	2014	15	No Range		ppb	11/4		10 Erosion of natural deposits, run from orchards, runoff from glass and electronics production wast
10 Banum	*	2014*	3119	0098 - 0119	191	~	7	2	Discharge of driting wester, discharge from metal refineries, erosion of natural deposits
13 Chromium	*	2014*	6.5	12-65	Pf	xe .	100	100	Discharge from steel and pulp mile excessor of natural deposits
14 Copper	N	2012/14*	6	•	P	<i>m</i>	13	AL*13	Corrosion of household prumbing systems, erosion of natural deposits, leaching from wood preservatives.
16 Fluoride	N	2014*	774	73 774	ps	yn.	4	4	Erosion of natural deposits, water additive which promotes strong teeth, discharge from fertilizer and aluminum factories
17 Lead	*	2012/14	3	0	P	*	0	AL*15	Corresion of household plumbling systems, expands of natural deposits
Disinfectio	n By-P	roducts							
81 HAAS	N	2014"	44 [1	to Range	ppb		1		By-Product of drinking water
8) Trass (Total Inhalomethanes)	N	2014"	796 /	to Hange	Dogs		7	80	digentachen. By-product of drinking water chlorination
Chlores	١	2015	•	6-13	mg/l		o wo		Water additive used to control microbes

*Most recent sample. No sample required for 2015.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

Significant Deficiencies

<u>During a sanitary survey conducted on 9/09/2015, the Mississippi State Department of Health cited the following significant deficiency(s).</u> Inadequate internal cleaning/maintenance of storage tanks

<u>Corrective actions:</u> MSDH is currently working with this system to return them to compliance since the expiration of the compliance deadline. We anticipate the system being returned to compliance by 6/30/2016.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or Other immune System disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791

The CS & I Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

RECEIVED-WATER SUPPLY 2016 JUL 14 AM 9: 06

PUBLISHER'S OATH

STATE OF MISSISSIPPI, CLAIBORNE COUNTY, MISSISSIPPI

Personally appeared before the undersigned NOTARY PUBLIC of said County, EMMA F. CRISLER, Publisher of The Reveille, a weekly newspaper, printed and published in the town of Port Gibson, in said county and state, who, being duly sworn deposes and says that said newspaper has been established for more than twelve months next prior to first publication mentioned below; and who further makes oath that publication of a notice, of which, the annexed is a copy, has been made in said paper consecutively, to wit:

On the	day of	010ء ر
On the	day of	, 2016
On the	day of	, 2016
On the	day of	, 2016
On the	$\underline{}$ 23 \mathbf{r}_{a} \mathbf{q}_{a}	<u>June</u> , 2016

_, Publisher

And do hereby centify that the papers containing said notice have been produced before me, and by me compared with the copy annexed, and that I find the proof of publication effector to be correctly made.

Windes my hand and self, this of Notary Public

Fees and proof of publication, \$ 319.00